



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2000779
Permit #: 00483-2024REM
Request Rec'd: 04/29/2024
Approval Date: 04/29/2024 DS
Permit Expires: 10/29/2024

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: JYB Holdings, LLC 1240 Rand Road Des Plaines, IL 60016 (None) County Contact: Joe Brancato 847/813-5247	FACILITY - name and address where tanks are located: Former Quik Mart #30134 1910-1990 W Central Road Arlington Heights, IL 60008 Cook County Contact: Dardis Brian M 312/577-1711
---	---

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
1	10,000	Gasoline	
2	10,000	Gasoline	
3	10,000	Gasoline	

Summary of Work

Removal of UST piping only.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Tsarpalas Enterprises, Inc. 17494 West Hickory Lane Grayslake, IL 60030	Contact Person: Steve Tsarpalas Phone: 847/816-8828 Email: tsarpalastank@yahoo.com Contractor License # IL297 Exp. 5/10/2024

Sincerely,



Daniel Starks