



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2013279  
Permit #: 00484-2024UPG  
Request Rec'd: 04/29/2024  
Approval Date: 04/29/2024 DS  
Permit Expires: 10/29/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061 Lake County Contact: John Graham 847/837-0777	<b>FACILITY</b> - name and address where tanks are located: Glenview Quik Shop 750 Waukegan Road Glenview, IL 60025 Cook County Contact: Ashok Patel 847/837-0777
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

### Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing


### Summary of Work

Installing new replacement SW STP Sumps on the three existing tanks. Installing new STP's inside new STP Sumps. Replacing the existing SW Spill buckets with new DW Spill Buckets and the existing Overfill Valves with new. Installing new position sensitive liquid sensors at new STP Sumps with positive shut-down. Revising the existing DWFRP piping only as needed to facilitate the install of new STP Sumps.

### Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2024

Sincerely,



Daniel Starks