

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 1044958
Permit #: 00486-2024UPG
Request Rec'd: 04/30/2024
Approval Date:04/30/2024 DS
Permit Expires: 10/30/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Casey's Retail Company

3305 SE Delaware Ave. P.O. Box 3004

Ankeny, IA 50021

Contact: Lee Lytle 515/446-6231

FACILITY

- name and address where tanks are located:

Casey's General Store #3048 601 W. Dakota St. Spring Valley, IL 61362

Bureau County

Contact: Audie Bradshaw 515/965-6238

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	12,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve

Summary of Work

Tank ID #2 ball float vent valve failed testing. Installing a new overfill drop tube valve and disabling or removing the ball float

Special Contingencies

Daniel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:

Total Petroleum Service Company
2421 Washington Road
Washington, IL 61571

Contact Person: Cheri McCoy
Phone: 309/694-8224
Email: Tom.Oltman@TotalPetroleum.net
Contractor License # IL1079 Exp. 2/8/2026

Sincerely,

Daniel Starks