



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 1023828
Permit #: 00488-2024UPG
Request Rec'd: 04/30/2024
Approval Date: 04/30/2024 DS
Permit Expires: 10/30/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois Department of Transportation 2300 S. Dirksen Parkway Springfield, IL 62764 Sangamon County Contact: Kyle Armstrong 217/557-2070 | FACILITY - name and address where tanks are located: IDOT Creston (231C) 5870 S. Mulford Rd. Creston, IL 60113 Ogle County Contact: Joshua Butterfield 815/284-5415 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 3 | Diesel Fuel | 12,000 | Currently in use | Federal |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 4B | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 |


Summary of Work

Replacing existing Veeder Root tank gauge console with new Veeder Root TLS 4B console

Special Contingencies

| | |
|--|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108 | Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026 |

Sincerely,



Daniel Starks