



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2020700  
Permit #: 00493-2024UPG  
Request Rec'd: 05/01/2024  
Approval Date: 05/01/2024  
Permit Expires: 11/01/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: City of Chicago Department of Water Management 1000 East Ohio Street Commissioner's Office Chicago, IL 60611 Cook County Contact: Chamoon Anawes 312/747-7154	<b>FACILITY</b> - name and address where tanks are located: City of Chicago Department of Water Management 3300 S. Cheltenham Place Chicago, IL 60649 Cook County Contact: Chamoon Anawes 312/747-0384
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	#2 Fuel Oil	8,000	Currently in use	Federal
3	#2 Fuel Oil	8,000	Currently in use	Federal
4	#2 Fuel Oil	8,000	Currently in use	Federal
5	#2 Fuel Oil	8,000	Currently in use	Federal
6	#2 Fuel Oil	8,000	Currently in use	Federal
7	#2 Fuel Oil	8,000	Currently in use	Federal
8	#2 Fuel Oil	8,000	Currently in use	Federal
9	#2 Fuel Oil	8,000	Currently in use	Federal
10	#2 Fuel Oil	8,000	Currently in use	Federal
11	Diesel Fuel	8,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100

**Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100

**Tank 10 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100

**Tank 11 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging L & J Engineering MCG8100


**Summary of Work**

Removing L&J tank gauge system and installing new Veeder Root TLS 450 Plus system.

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
K Plus Mechanical 10220 Bode St. Unit A Plainfield, IL 605851632	Contact Person: Tim Smith Phone: 815/216-7715 Email: tsmith@kplusmechanical.com Contractor License # IL002455 Exp. 10/26/2024

Sincerely,



Sean Keane