



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 3038995 |
| Permit #: | 00494-2024UPG |
| Request Rec'd: | 05/01/2024 |
| Approval Date: | 05/01/2024 DS |
| Permit Expires: | 11/01/2024 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Brewer's Distributing 2421 West Townline Road Peoria, IL 61615 Peoria County Contact: Brad Aschenbrenner 309/692-2883 | FACILITY - name and address where tanks are located: Brewer's Distributing 2421 West Townline Road Peoria, IL 61615 Peoria County Contact: Brad Aschenbrenner 309/692-2883 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Diesel Fuel | 12,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 5,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|--------|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | New |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|--------|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | New |

Summary of Work

Installing future conduit penetrations at the existing STP sumps. All tanks, piping and containment sumps are existing. All setbacks are met or existing.

Special Contingencies

NOTE: No sensors are being installed. Conduit is being installed for possible future dispensers and the existing submersible sumps will be penetrated.

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Total Petroleum Service Company 2421 Washington Road Washington, IL 61571 | Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2026 |

Sincerely,

Daniel J. Starks

Daniel Starks