



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2039062
Permit #: 00520-2024UPG
Request Rec'd: 05/03/2024
Approval Date: 05/05/2024 DS
Permit Expires: 11/06/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County Contact: Zachary M. Davis 937/203-7827	FACILITY - name and address where tanks are located: Speedway #1422 900 Brook Forest Ave. Shorewood, IL 60404 Will County Contact: Julie Rein 937/863-6513
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	20,000	Currently in use	Federal
2	Gasoline - Premium	12,000	Currently in use	Federal
3	Gasoline - Mid-grade	12,000	Currently in use	Federal
4	B-11	12,000	Currently in use	Federal
5	Kerosene	2,000	Currently in use	Federal
6	Racing Fuel	2,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD

Summary of Work

Replace TLS350with CSLD with TLS450+CSLD. Replace PLLD with DPLLD.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/243-9081 Email: steve@andersonpump.com Contractor License # IL002275 Exp. 5/21/2024

Sincerely,



Daniel Starks