



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2044934  
Permit #: 00529-2024UPG  
Request Rec'd: 04/28/2024  
Approval Date: 05/05/2024 DS  
Permit Expires: 11/06/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Elmhurst Memorial Hospital 155 E. Brush Hill Road Elmhurst, IL 60126 Du Page County Contact: Tim Johnson 331/221-0832	<b>FACILITY</b> - name and address where tanks are located: Elmhurst Memorial Hospital 155 E. Brush Hill Road Elmhurst, IL 60126 Du Page County Contact: Patrick 331/221-0832
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	30,000	Currently in use	Federal
2	Diesel Fuel	30,000	Currently in use	Federal
3	Diesel Fuel	40,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - North	Replacing - Spill Contain Device - Single Wall Spill Bucket - North
Overfill Prevention Device	Overfill Drop Tube Valve - North	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - Center	Replacing - Spill Contain Device - Single Wall Spill Bucket - Center
Overfill Prevention Device	Overfill Drop Tube Valve - Center	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - Center

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - South	Replacing - Spill Contain Device - Single Wall Spill Bucket - South
Overfill Prevention Device	Overfill Drop Tube Valve - South	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - South

**Summary of Work**


Remove (3) tank top overfills and (3) remote overfills. Install (3) new double wall tank top overfills and (3) new double wall overfills for the remote fills.

**Special Contingencies****PERSON, FIRM OR COMPANY PERFORMING WORK:**

Metro Environmental Contractors, Inc. dba Metro Tank &  
Pump Company  
1111 West Dundee Road  
Wheeling, IL 600903936

Contact Person: Warren Cherner  
Phone: 847/465-4000  
Email: warren@metrotank.com  
Contractor License # IL102 Exp. 2/7/2026

Sincerely,



---

Daniel Starks