

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

Amended

FOR OFFICE USE ONLY

Facility # 2-043129
Permit # 01903-2006INS
Request Rec'd 12/18/2006
Amended Date 01/03/2007
Approval Date 12/20/2006 JC
Permit Expires 6/20/2007

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

THIS	PERMIT IS VALID FOR SIX MONTHS FROM THE APPRO	OVAL DATE.	
(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:		(2) <u>FACILITY</u> - name and address where tanks are located:	
INAMCO Chicago, Inc.		Manheim Dickerson Gas	
1211 Hileah Lane		2201 North Mannheim	
Hanover Park, IL 60103		Melrose Park, Cook Co., IL	
Contact: Joseph George		Contact:	
3) <u>IN</u>	STALLATION OF TANKS:		
(a	Number and size of tanks being installed: (TK # 1) - 17 5,000 gallons	2,000 gallons, (TK # 2) - 4,000 gallons, (TK # 3) - 8,000 gallons, ((TK # 4) -
(b)	Type of tanks: (TK # 1, 2, 3, 4) - (Installing) XERXES double wall fiberglass (TK # 2, 3, 4) - Tanks 2,3,4 comprise one compartment tank		
(c	Type of piping: (TK # 1, 2, 3, 4) - (Installing) A.P.T. Poly Tech P175 SC double wall flexible		
(d	Product to be stored in each tank: (TK # 1, 2, 3) - Gaso	oline, (TK # 4) - Diesel Fuel	
(e	Type of leak detection being used:		
	<i>Tank:</i> (TK # 1, 2, 3, 4) - (Installing) Veeder Root TLS 300 automatic tank gauge, (TK # 1, 2, 3, 4) - (Installing) Veeder Root TL 300 Interstitial tank sensor		
	Piping: (TK # 1, 2, 3, 4) - (Installing) FE Petro STP-1 Root TLS 300 interstitial piping sump sensor and at all dispenser sumps.	MLD mechanical line leak detector, (TK # 1, 2, 3, 4) - (Installing) (TK # 1, 2, 3, 4) - Sensors will be installed at all submersible	
(f)	Corrosion Protection being used:		
	Tank:		
	<i>Piping:</i> (TK # 1, 2, 3, 4) - (Installing) Non-corrosive	flexible	
(g) Spill containment devices:		
(h) Overfill prevention devices:		
an	ne owner must notify this Office when completion of tank insta	llation has occurred, on the Notification for Underground Storage Talle for installation to the OSFM prior to the work being performed. 1020.	
in wa co co pi	ches in diameter, installed in each new tank field of tanks la atter tight containment shall be installed under all dispensers ontainments. All steel piping for vents, risers, and fills in co- pated. A positive shut off valve shall be installed on pressur	of two manufactured slotted or perforated observation wells of at arger than 1000 gallons and one well for tanks less than 1000 gallons and at submersible pumps. A hydrostatic test must be performed intact with the ground, backfill, or water shall be dielectrically wratized product lines, at the submersibles, or installed at the tank for k to grade level. All steel flex connectors in contact with ground, but the ground, but the ground is the submersible of the grade level.	ns. A on all pped or all suction
6) <u>SI</u>	PECIAL CONTINGENCIES:		
(7) <u>P</u>	ERSON, FIRM OR COMPANY PERFORMING WORK:		
		Contact Person:	
		Phone:	
		Contractor Registration #	1

Sincerely,

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)