



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605
Amended

FOR OFFICE USE ONLY
Facility # 2-030101
Permit # 01496-2006UPG
Request Rec'd 10/05/2006
Amended Date 11/08/2006
Approval Date 10/12/2006 JC
Permit Expires 4/12/2007

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sheraton Suites 121 Northwest Point Boulevard Elk Grove Village, IL 60007 Contact: David Contreras (847) 290-7073	(2) FACILITY - name and address where tanks are located: Sheraton Suites 121 Northwest Point Boulevard Elk Grove Village, Cook Co., IL Contact: David Contreras (847) 290-7073
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1) - 2,500 gallons
- (b) **Type of tanks:** (TK # 1) Existing Existing double wall fiberglass
- (c) **Type of piping:** (TK # 1) Existing Existing steel primary within fiberglass secondary, (TK # 1) Existing Single wall fiberglass
- (d) **Product to be stored in each tank:** (TK # 1) - Diesel Fuel
- (e) **Type of leak detection being used:**
Tank: (TK # 1) - (Installing) Incon TSP-EIS Interstitial tank sensor, (TK # 1) - (Installing) Incon TS 750 automatic tank gauge, (TK # 1) Existing Existing vapor monitoring (TK # 1) - Installing a console / printer, and a probe only (inventory only) for the automatic tank gauge.
Piping: (TK # 1) - (Installing) Incon TSP ULS Interstitial Sensor, (TK # 1) Existing Existing vapor monitoring (TK # 1) - Interstitial sensor will be at submersible sump only.
- (f) **Corrosion Protection being used:**
Tank: _____
Piping: (TK # 1) Existing Fiberglass (TK # 1) Existing Existing fiberglass
- (g) **Spill containment devices:** _____
- (h) **Overfill prevention devices:** _____
- (i) **Manway accessible at grade:** _____

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: _____

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: _____ _____ _____	Contact Person: _____ Phone: _____ Contractor Registration # _____ Exp. _____
--	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)