



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 2-016007
Permit # 00383-2006LIN
Request Rec'd 03/15/2006
Amended Date 05/04/2006
Approval Date 3/16/2006 JC
Permit Expires 9/16/2006

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Part 170. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Mohammed Motan 14422 S Tripp Ave Midlothian, IL 60445</p> <p>Contact: Mohammed Motan (708) 371-7188</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Crestwood Marathon 14144 S Pulaski Rd Crestwood, Cook Co., IL</p> <p>Contact: Mohammed Motan (708) 388-9511</p>
---	---

(3) INSPECTION OF INTERIOR LINING OF TANKS:

- (a) *Number and size of tanks being inspected:* (TK # 1) - 8,000 gallons
- (b) *Type of tanks:* (TK # 1) - Existing single wall steel
- (c) *Product stored in each tank:* (TK # 1) - Gasoline
- (d) *Manway accessible at grade:*

(4) Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading, or interior lining is authorized with this permit.

(5) The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(6) SPECIAL CONTINGENCIES: Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). An amendment request was received from STSS Southern to indicate that only tank #1 was inspected on this permit. It failed the inspection and will be relined. It has been determined tanks 2,3,4 were lined 07/14/99 through permit #01961-1999REL and tank #1 was originally lined 09/07/93 from permit #9664-93REL. According to our records tank #1 was lined 09/07/93 (permit #9664-93REL), tanks 1,2,3 were lined 07/14/99 (permit #01961-1999REL). There is no evidence that tank #4 has ever been lined unless a clerical error was made by the inspector and permit reviewer for permit #01961-1999REL; consequently, we have no evidence of any corrosion protection for tank #4.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>MPC Construction, Inc. 921 W. 8th Street</p> <p>_____</p>	<p>Contact Person: Brian McCormick Phone: _____ Contractor Registration # _____ Exp.</p>

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)