



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Extended

FOR OFFICE USE ONLY
Facility #: 2016787
Permit #: 01324-2023UPG
Request Rec'd: 11/16/2023
Approval Date: 11/16/2023 DS
Extension Date: 05/08/2024
Permit Expires: 11/18/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Sat Kaival Real Estate, LLC 200 E. Fabyan Pkwy Batavia, IL 60510 (None) County Contact: Nehal Patel 630/697-6477 | FACILITY - name and address where tanks are located: Sat Kaival Real Estate, LLC 200 Fabyan Pkwy. Batavia, IL 60510 Kane County Contact: Nehal Patel 630/697-6477 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 8 | Diesel Fuel | 8,000 | Currently in use | Federal |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--------|
| Piping | Flexible Double Wall A.P.T. Poly Tech XP 1500 | New |
| Piping | Shear Valves | New |
| Piping | Ball Valves | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|--------|
| 17/18 | New |

Dispenser 17/18 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Summary of Work

Installing new 3K DEF tank. Installing new high speed diesel fueling point. New flexible double wall pipe from the existing diesel stp sump run approx 65' to the new dispenser containment sump.

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|---|---|
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2024 |

Sincerely,



Daniel Starks

| | | |
|----------------------------------|---|---------------|
| For Office Use Only | | |
| Tank 8 Equipment | | |
| Equipment Type | Permit Equipment | Action |
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump | Removing |
| Dispenser 17/18 Equipment | | |
| Equipment Type | Permit Equipment | Action |