



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	3000813
Permit #:	00548-2024UPG
Request Rec'd:	05/09/2024
Approval Date:	05/09/2024 DS
Permit Expires:	11/12/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Guraya, Inc. 1009 Division Street Orion, IL 61273 Henry County Contact: Harbhajan Singh 309/314-3707	FACILITY - name and address where tanks are located: Alpha Mart Phillips 66 202 S. 1st Street Alpha, IL 61413 Henry County Contact: Inderjeet Victor 309/529-2225
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	8,000	Currently in use	Federal
2	Gasoline - Premium	8,000	Currently in use	Federal
3	Gasoline - Mid-grade	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 300c with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Gilbarco Tank Monitor 2

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 300c with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Gilbarco Tank Monitor 2

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 300c with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Gilbarco Tank Monitor 2

Summary of Work

We will replace the existing TLS 250 with a rebuilt TLS 300C with CSLD and new probes.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Pipeco, Inc.
610 29th Street
Bettendorf, IA 52722

Contact Person: Robert Schafer
Phone: 563/529-8502
Email: rob@pipoecoinc.com
Contractor License # IL2034 Exp. 9/28/2024

Sincerely,



Daniel Starks