



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Extended**

**FOR OFFICE USE ONLY**  
Facility #: 2000179  
Permit #: 00565-2024UPG  
Request Rec'd: 05/10/2024  
Approval Date: 05/10/2024 DS  
Extension Date: 05/11/2024  
Permit Expires: 05/13/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Otto Engineering, Inc. 2 E. Main St. Carpentersville, IL 60110 Kane County Contact: Thomas J. Roeser 847/428-7171	<b>FACILITY</b> - name and address where tanks are located: H & Sons, Inc. 72 Kimball Street Elgin, IL 60120 Kane County Contact: Ahmed Shakoore 847/742-4343
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	6,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Extractor Fitting Valves	New

**Summary of Work**

Diesel Vapor lines are tied to regular and premium. We want to isolate diesel vapor lines from regular and premium. work will include identifying and pinpointing the extractor fitting for diesel tank. tanknology will run the camera in the tank to pinpoint the extractor fittings. Once identified, we will have to isolate the vapor lines

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
American Petroleum Solutions LLC 180 Forest Trail Oak Brook, IL 60523	Contact Person: Haibat Khan Phone: 909/312-9449 Email: apetro.office@gmail.com Contractor License # IL002454 Exp. 5/16/2024

Sincerely,

Daniel Starks