



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 3014096  
Permit #: 00571-2024CAT  
Request Rec'd: 05/13/2024  
Approval Date: 05/13/2024 DS  
Permit Expires: 11/13/2024

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Arya-Anika, Inc. d/b/a Mini Mart 525 W. Main Street Geneseo, IL 61254 Henry County Contact: Ritesh Patel 224/388-9817	<b>FACILITY</b> - name and address where tanks are located: Mini Mart 525 W. Main Street Geneseo, IL 61254 Henry County Contact: Ritesh Patel 224/388-9817
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Premium	4,000	Currently in use	Federal
5	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	New

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	New

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**  
add anode to UDC 1/2 & Reg STP

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: 563/344-0700 Email: lynn@pipecoinc.com Contractor License # IL2034 Exp. 9/28/2024

Sincerely,

*Daniel J. Starks*

Daniel Starks