



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 2034132 |
| Permit #: | 00575-2024UPG |
| Request Rec'd: | 05/13/2024 |
| Approval Date: | 05/13/2024 DS |
| Permit Expires: | 11/13/2024 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: SASK Properties, LLC 24911 Donegal Way Plainfield, IL 60585 Will County Contact: Rizwan Khan 630/802-0000 | FACILITY - name and address where tanks are located: KNK Gas and Wash d/b/a Marathon 2151 W. Army Trail Road Addison, IL 60101 Du Page County Contact: Rizwan Khan 630/801-0000 |
|---|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|----------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 2 | Gasoline - Mid-grade | 6,000 | Currently in use | Federal |
| 3 | Gasoline - Premium | 6,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Sump Sensor |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Sump Sensor |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors |
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Piping | Ball Valves | New |
| Piping | Flex Connector Steel | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Sump Sensor |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Sump Sensor |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors |
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Sump Sensor |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Sump Sensor |


Summary of Work

Replacing tank monitor, probes, leak detectors, and sensors on each tank. Converting T2 midgrade to E85, replacing submersible and drop tube

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|---|---|
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2026 |

Sincerely,



Daniel Starks