



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	3038995
Permit #:	00494-2024UPG
Request Rec'd:	05/01/2024
Approval Date:	05/01/2024 DS
Amended Date:	05/14/2024 DS
Permit Expires:	11/01/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Brewer's Distributing 2421 West Townline Road Peoria, IL 61615 Peoria County Contact: Brad Aschenbrenner 309/692-2883	FACILITY - name and address where tanks are located: Brewer's Distributing 2421 West Townline Road Peoria, IL 61615 Peoria County Contact: Brad Aschenbrenner 309/692-2883
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	12,000	Currently in use	Federal
2	Gasoline - Regular	5,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Summary of Work

Installing future conduit penetrations at the existing STP sumps. All tanks, piping and containment sumps are existing. All setbacks are met or existing.

Special Contingencies

Amendment Reason:

Penetration to subsurface sumps is not necessary. Requesting to amend permit to replace shear valves at dispensers due to valves being in poor condition.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2026

Sincerely,

Daniel J. Starks

Daniel Starks