



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2026498
Permit #: 00582-2024REM
Request Rec'd: 05/14/2024
Approval Date: 05/14/2024 DS
Permit Expires: 11/14/2024

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Feece Oil Company 517 Twin Rail Drive Minooka, IL 60510 Kane County Contact: Feece Mike 630/879-1911	FACILITY - name and address where tanks are located: Feece Oil Company 1700 Hubbard Batavia, IL 60510 Kane County Contact: Michael Feece 630/879-1911
--	--

IEMA Number
1994-1041

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
6	12,000	Diesel Fuel	
7	6,000	Gasoline - Regular	
8	6,000	Gasoline - Premium	

Summary of Work

Removing existing FRP DW products lines, poly containment sumps, and FRP vent lines. Installing new on separate permit.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Oil Equipment Company, Inc. 4701 Lien Road Madison, WI 53704	Contact Person: TJ Winkler Phone: 815/298-3767 Email: pobrien@oilequipment.com Contractor License # IL1318 Exp. 3/5/2026

Sincerely,

Daniel Starks