



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2037166
Permit #: 00586-2024UPG
Request Rec'd: 05/15/2024
Approval Date: 05/15/2024 DS
Permit Expires: 11/15/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: RPT Enterprises, LLC 475 Supreme Drive Bensenville, IL 60106 Du Page County Contact: Deepak Shah 847/650-0104	FACILITY - name and address where tanks are located: Elgin Convenience 1 1190 N. McLean Blvd. Elgin, IL 601231723 Kane County Contact: Hemendra Shah 847/791-6639
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	15,000	Currently in use	Federal
2	Gasoline - Premium	15,000	Currently in use	Federal
3	Diesel Fuel	15,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Piping	Extractor Fitting Valves	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Piping	Extractor Fitting Valves	New

Summary of Work

Replace probe risers, vapor risers and extractor fittings on Regular and Diesel tanks. Replace probe riser on Premium tank. Repair all 3 vents by replacing cracked 90 degree fittings at the bottom of the vent risers.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
1058 National Parkway
Schaumburg, IL 601734519

Contact Person: Chris Derro
Phone: 708/603-4111
Email: ccabay@cardinalcompliance.net
Contractor License # IL002418 Exp. 3/21/2025

Sincerely,



Daniel Starks