



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047563
Permit #: 00591-2024UPG
Request Rec'd: 05/15/2024
Approval Date: 05/15/2024 DS
Permit Expires: 11/15/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois State Tollway Highway Authority 2700 Ogden Avenue Downers Grove, IL 60515 Du Page County Contact: Manar Nashif 630/241-6800Ext.4841	FACILITY - name and address where tanks are located: ISTHA M5 Maintenance Garage 575 W. Central Road Route 90, MP 64.5 (Central Road) Hoffman Estates, IL 60192 Cook County Contact: Gery Schauch 847/605-9170
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	12,000	Installed/Not in Use	Federal
2	Gasoline - Regular	10,000	Installed/Not in Use	Federal
3	E85	10,000	Installed/Not in Use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	New
Leak Detection - Piping	European with No Test Req Suction	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	New

Summary of Work

Adding overfill valves on (3) tanks.

Adding American suction pipe for tank #1 only for a filtration system. There is an existing tank top sump and transition sump both with sensors that is existing. Sensors are positive shutdown.

We are NOT adding sensors under this permit. The sensors are existing but the permit application insisted I add the sensors with positive shutdown.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd.
651 S. Sutton Road #214
Streamwood, IL 60107

Contact Person: Robert Sumoski
Phone: 630/201-4967
Email: yvonne@crownetank.com
Contractor License # IL002345 Exp. 5/16/2024

Sincerely,



Daniel Starks