



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2005467
Permit #: 00598-2024ABN
Request Rec'd: 05/15/2024
Approval Date: 05/16/2024 DS
Permit Expires: 11/18/2024

Permit for ABANDONMENT-IN-PLACE of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60642 Cook County Contact: Roy Hupke 708/229-5241	FACILITY - name and address where tanks are located: Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60805 Cook County Contact: William Heisterman 708/229-5241
--	---

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Fill Material	Comments
6	10,000	Diesel Fuel	Piping Capped Off	

Explanation of Waiver for Abandonment

Portion of Old fuel pipe runs under building addition and removal is not possible.
Portion of old pipe runs across emergency room entrance and removal will disrupt emergency room access.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: yvonne@crownetank.com Contractor License # IL002345 Exp. 9/8/2025

Sincerely,

Daniel Starks