

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

 FOR OFFICE USE ONLY

 Facility #:
 2033532

 Permit #:
 00599-2024INS

 Request Rec'd:
 04/10/2024

 Approval Date:05/16/2024 DS
 Permit Expires:

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: https://webapps.sfm.illinois.gov/USTPortal/NotificationForm.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	FACILITY - name and address where tanks are located:
Village of Wheeling 77 W. Hintz Rd. Wheeling, IL 60090 Cook County	Village of Wheeling 95 Old Willow Rd Wheeling, IL 60090 Cook County
Contact: Lana Rudnick 847/229-4600	Contact: Isac Santos 847/229-4600

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	1,000	Tank Not Installed	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank Automatic Tank Gauging Veeder Root TLS 450 Plus		New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Leak Detection - Piping	American with Sensors/No Test Suction	New
Spill Containment Device	Double Wall Spill Bucket	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Overfill Prevention Device	Overfill Alarm	New
Corrosion Protection - Tank	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	ion - Piping Flexible Non-Corrosive	
Tank	Fiberglass Double Wall XERXES	New
Piping	Flexible Double Wall Franklin Fueling Systems UPP	New
Piping	Ball Valves	New
iping Valves Foot Valve		New
Piping	Single Wall STP/Tanktop Sump	New
➡ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Piping	Single Wall Transition Sump	New
➡ Leak Detection - Piping Sump Sensor with positive shutdown		New

General Requirements

<u>USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions.</u> There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

(1) 1,000 gallon capacity, Double Wall, Fiberglass Tank. (1) 22" Manway on tank. (1) 42" Water Tight Piping Sumps. (2) Observation Wells within tank field.

OVERSPILL & OVERFILL PROTECTION: (1) 5 gallon below grade water tight double wall Spill Manhole with Cap and Adapter. (1) Overfill valves.

CONTAINMENT SUMPS: (1) 42" fiberglass water-tight piping sump on tank top. (1) Fiberglass transition sumps at building. PIPING: Fuel Piping: Approximate run 25' each. Fuel Supply piping = (2) 1" double wall Omegaflex piping run from tank to building. Fuel Supply & Fuel Oil Return piping. Ball valves within tank top sump.

TANK MONITORING SYSTEM (1) Veeder Root TLS 450 plus. (1) In Tank Level Probe with Float Kit. (1) Interstitial Sensor. (2) Sump Sensors.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	R COMPANY PERFORMING WORK:	
651 S. Sutton Road #214	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 5/16/2026	

Sincerely,

Daniel J. Starke

Daniel Starks