



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2010832
Permit #: 00600-2024UPG
Request Rec'd: 05/15/2024
Approval Date: 05/16/2024
Permit Expires: 11/18/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Marco D'Agostino 7130 N. Western Ave. Chicago, IL 60645 Cook County Contact: Marco D'Agostino 773/274-4340 | FACILITY - name and address where tanks are located: Touhy Western Marathon Service Station 7130 N. Western Avenue Chicago, IL 60645 Cook County Contact: Riyaz Desai 773/274-4340 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|----------------------|----------|------------------|------------------|
| 10 | Gasoline - Mid-grade | 10,000 | Currently in use | Federal |

Tank 10 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--|--|
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors | Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors |
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Piping | Ball Valves | New |
| Piping | Flex Connector Steel | New |
| Piping | Other Submersible Pump | New |
| Piping | Shear Valves | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350R with CSLD |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Sump Sensor |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall Transition Sump | Replacing - Leak Detect - Piping - Sump Sensor |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Sump Sensor |
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall Transition Sump | Replacing - Leak Detect - Piping - Sump Sensor |

Summary of Work

Replacing necessary existing equipment for the Midgrade tank with E85 compatible equipment.


Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: ben.olthoff@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive, flowing style. Below the signature is a solid horizontal line.

Sean Keane