

Office of the Illinois State Fire Marshal **Division of Petroleum and Chemical Safety**

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Replacement of 01276-2022UPG FOR OFFICE USE ONLY

Facility #: 2005467 Permit #: 00601-2024UPG Request Rec'd: 05/16/2024 Approval Date:05/16/2024 DS Permit Expires: 11/18/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for **Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60642

Cook County

Contact: Roy Hupke 708/229-5241

FACILITY

- name and address where tanks are located: Little Company of Mary Hospital

2800 W. 95th Street Evergreen Park, IL 60805 Cook County

Contact: William Heisterman 708/229-5241

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	10,000	Currently in use	Federal

Summary of Work

The underground tank has (1) existing 1 inch fuel supply line to the building generator. The existing fuel line will be replaced by the new. The new pipe will be (1)1 inch Omegaflex brand pipe from the UST to the building. The route for the new pipe is not in the same trenchas the old pipe. When the new pipe is installed the old pipe will be disconnected form the tank and drained and then abandonned inplace under a separate permit. The change over from the old pipe to the new pipe will happen within a few hours so as not to take thegenerator system off line for more than 2 hours. There is no change to the tank top containment. The tank top containment is only acyliner to keep gravel away and not a containment sump. There is NO change to the vent pipe, fill or other fuel system components. There is NO fuel return line.

Special Contingencies

Replaced piping exceeds 20 feet or 50% of the total pipe run.

Replacement Reason:

Permit 01276-2022UPG voided at the time of final

PERSON, FIRM OR COMPANY PERFORMING WORK:

ief y. Starke

Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107

Contact Person: Robert Sumoski

Phone: 630/201-4967

Email: yvonne@crownetank.com

Contractor License # IL002345 Exp. 5/16/2026

Sincerely,

Daniel Starks