



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2023112
Permit #: 00603-2024UPG
Request Rec'd: 05/16/2024
Approval Date: 05/16/2024 DS
Permit Expires: 11/18/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Shehdeh Abu-Khalil 13822 Janas Parkway Homer Glen, IL 60491 Will County Contact: Shehdeh Abu-Khalil 708/989-9009	FACILITY - name and address where tanks are located: BP Amoco 543 S. Bolingbrook Drive Bolingbrook, IL 60439 Will County Contact: Mohammed Fryhat 708/989-9009
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection


Summary of Work

The site WPPLD failed so cheging to mechanical as WPPLDis not available to replace

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025

Sincerely,



Daniel Starks