



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2005761  
Permit #: 00623-2024CAT  
Request Rec'd: 05/22/2024  
Approval Date: 05/22/2024 DS  
Permit Expires: 11/22/2024

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Round Lake Area School District 116 316 S. Rosedale Court Round Lake, IL 60073 Lake County Contact: Marc Weihofen 708/546-5522	<b>FACILITY</b> - name and address where tanks are located: Round Lake Area School District 116 811 N. Sunset Dr. Round Lake, IL 60073 Lake County Contact: Marc Weihofen 708/546-5522
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	8,000	Currently in use	Federal

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	New

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

Installing sacrificial anodes on flex connector in tank top sump of diesel tank

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks