



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2006943
Permit #:	00630-2024UPG
Request Rec'd:	05/23/2024
Approval Date:	05/24/2024 DS
Permit Expires:	11/26/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Midlothian Real Estate, LLC 4000 W. 147th Street Midlothian, IL 60445 Cook County Contact: Muhannad Awadallah 708/228-4444	<b>FACILITY</b> - name and address where tanks are located: 147th St Fuel, Inc. 4000 W. 147th Street Midlothian, IL 60445 Cook County Contact: Said Alharsha 708/228-4444
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Gasoline - Premium	10,000	Currently in use	Federal
7	Diesel Fuel	8,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing

**Summary of Work**

Remove ball only from ball floats on all tanks.

**Special Contingencies**

**NOTE: Site has existing drop tubes**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/243-9081 Email: steve@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks