



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2038991
Permit #: 00635-2024UPG
Request Rec'd: 05/25/2024
Approval Date: 05/26/2024 DS
Permit Expires: 11/27/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Glogovsky Real Estate, LLC 28787 N. Waukegan Rd. Lake Bluff, IL 60044 Lake County Contact: Jeff Glogovsky 847/276-0310	FACILITY - name and address where tanks are located: Glogovsky Petroleum Co., Inc. d/b/a Lake Bluff Shell 28787 North Waukegan Road Lake Bluff, IL 60044 Lake County Contact: Jeff Glogovsky 847/276-0310
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	8,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Flexible Double Wall Environ Geo Flex

Summary of Work

Replacing the existing Diesel line / piping (Environ Flexible) with DW Nupi Smartflex pipe between the existing Diesel STP Sump and the existing Diesel Dispenser / Dispenser sump. The existing PLLD and liquid sensors are to remain.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2024

Sincerely,



Daniel Starks