



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2026413
Permit #:	00643-2024CAT
Request Rec'd:	05/28/2024
Approval Date:	05/28/2024 DS
Permit Expires:	11/30/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	FACILITY - name and address where tanks are located: Bucky's Express #6437 485 Townline Road (State Route 60) Mundelein, IL 60061 Lake County Contact: Abraham Mookan 515/446-6238
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Diesel Fuel	10,000	Currently in use	Federal
4	Gasoline - Premium	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 11/12	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp 11/12
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 3/4	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp 3/4
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 5/6	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp 5/6
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 7/8	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp 7/8
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 9/10	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp 9/10

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 1/2	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp 1/2
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

NACE Certified Designer

NACE Certified Designer Number

Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work


Install replacement 9lb block anodes on flex connectors in Diesel STP, PUL STP, and Dispensers 1/2, 3/4, 5/6, 7/8, 9/10, & 11/12

PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, LLC
658 North Progress Drive PO Box 80265
Saukville, WI 53080

Contact Person: Kylie Krombach
Phone: 262/268-1150
Email: danc@protanicinc.com
Contractor License # IL1413 Exp. 3/15/2026

Sincerely,



Daniel Starks