



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2022871
Permit #:	00677-2024UPG
Request Rec'd:	06/04/2024
Approval Date:	06/04/2024 DS
Permit Expires:	12/04/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Shree Real Estate Channahon Corporation 24061 W. Eames Street Channahon, IL 60410 Will County Contact: Dileep Shrivastava 847/644-4193	FACILITY - name and address where tanks are located: Channahon Petroleum, Inc. - BP 24061 W. Eames Street Channahon, IL 60410 Will County Contact: Thomas Thattil 815/467-7191
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
12	Gasoline - Regular	10,000	Currently in use	Federal
13	Gasoline - Regular	10,000	Currently in use	Federal
14	Gasoline - Premium	10,000	Currently in use	Federal

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Piping	Steel Single Wall Piping	New
Piping	Flex Connector Steel	New

Tank 13 Equipment

Equipment Type	Permit Equipment	Action
Piping	Steel Single Wall Piping	New
Piping	Flex Connector Steel	New

Tank 14 Equipment

Equipment Type	Permit Equipment	Action
Piping	Steel Single Wall Piping	New

Summary of Work

Dispensers were removed in installation mounting plates were anchor to concrete , shear valves were raised 2 inches, and dispenser reinstalled

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Reliable Pump Service and Maintenance
14007 S Bell Road Suite 228
Homer Glen, IL 60491

Contact Person: John Baio, Jr.
Phone: 815/546-7867
Email: Reliablepumpservice@yahoo.com
Contractor License # IL002433 Exp. 10/7/2024

Sincerely,



Daniel Starks