



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2023099  
Permit #: 00719-2024UPG  
Request Rec'd: 06/12/2024  
Approval Date: 06/12/2024 DS  
Permit Expires: 12/12/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: 2231 Properties, LLC 2231 Maple Avenue Downers Grove, IL 60515 (None) County Contact: Sebil Joseph 847/682-6504	<b>FACILITY</b> - name and address where tanks are located: 2231 Properties, LLC 2231 Maple Avenue Downers Grove, IL 60515 Du Page County Contact: Vimal Silvester 847/652-6504
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	12,000	Currently in use	Federal
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Gasoline - Premium	12,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Other Non-vented check valve

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

**Summary of Work**

Replecing the leak detector to PLLDs from WPPLDs

**Special Contingencies**

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

America Petropump Services LLC d/b/a Ampsco Services  
4075 Fox Valley Center Dr., Unit 9  
Aurora, IL 60504

Contact Person: Ravindra Penmatsa  
Phone: 312/286-6722  
Email: ravi@ampsco.net  
Contractor License # IL002420 Exp. 5/22/2025

Sincerely,



---

Daniel Starks