



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2006999
Permit #: 00720-2024LIN
Request Rec'd: 05/14/2024
Approval Date: 06/13/2024 DS
Permit Expires: 12/13/2024

**Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for
Petroleum and Hazardous Substances**

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. **THIS PERMIT IS FOR THE INTERIOR INSPECTION OF THE EXISTING LINING ONLY! NO REPAIRING, UPGRADING, OR INTERIOR LINING IS AUTHORIZED WITH THIS PERMIT.**

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: JBK Calumet Properties, Inc. 1620 W. 127th Street Calumet Park, IL 60645 Cook County Contact: 773/968-7772	FACILITY - name and address where tanks are located: Shell Station 1620 W. 127th Street Calumet Park, IL 60643 Cook County Contact: Jaimon Thodukayil 773/968-7772
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
1	Gasoline - Regular	10,000	Currently in use	Federal	Existing
2	Gasoline - Regular	10,000	Currently in use	Federal	Existing
3	Gasoline - Premium	8,000	Currently in use	Federal	Existing

Summary of Work

Purge, clean and inspect the internal lining of the following tanks in accordance with NLPA-631 and State of Illinois 175 regulations:

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086	Contact Person: Clayton Bennett Phone: 262/623-0300 Email: paula@armorshieldus.com Contractor License # IL1707 Exp. 4/18/2026

Sincerely,

Daniel Starks