



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 4043622  
Permit #: 00721-2024ABN  
Request Rec'd: 06/12/2024  
Approval Date: 06/13/2024 DS  
Permit Expires: 12/13/2024

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909 Knox County Contact: Joey Cupp 865/588-7488	<b>FACILITY</b> - name and address where tanks are located: Pilot Travel Center #368 4030 E. Boyd Road Decatur, IL 62526 Macon County Contact: Leigh West 865/588-7488
--	--

**Tanks on the Permit**

Tank #	Capacity	Product	Fill Material	Comments
5	20,000	Diesel Fuel	Inert material mixed with portland cement	CLOSING IN PLACE
6	20,000	Diesel Fuel	Inert material mixed with portland cement	CLOSING IN PLACE

**Explanation of Waiver for Abandonment**

PROXIMITY TO OTHER ACTIVE TANKS WILL NOT ALLOW FOR SAFELY REMOVING.

**Location of Tanks Being Abandoned**

Tanks are located in cloxe proximity to an active tank, as shown in site plan. Attempting to remove these tanks would undermine the structural integrity of the active tank.

**Location of Piping Being Abandoned**

**NOTE: Exisiting piping will need an upgrade permit to tie into the active piping, it will not be allowed to be done under the install of other tanks.**

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026

Sincerely,



Daniel Starks