

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2014719
Permit #: 00730-2024UPG
Request Rec'd: 06/17/2024
Approval Date:06/17/2024 SB
Permit Expires: 12/17/2024

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

RDK Ventures, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 Du Page County

Contact: Elizabeth Sauser 708/748-3496

**FACILITY** 

- name and address where tanks are located:

Circle K #6718 7654 West Route 30 Frankfort, IL 60522 Will County

Contact: Pam Gonzales 812/379-9227

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Premium	12,000	Currently in use	Federal

#### **Tank 8 Equipment**

<b>Equipment Type</b>	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New

### **Summary of Work**

Installing new fill riser, replacing spill bucket and overfill drop tube on Premium tank # 8.

#### **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: keith@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026			

Sincerely,

Shelly Bradley

Shelly Bradley