



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2044189
Permit #:	00735-2024INS
Request Rec'd:	06/14/2024
Approval Date:	06/18/2024 DS
Permit Expires:	12/18/2024

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: DOT Foods, Inc. PO Box 192 Mount Sterling, IL 62353 Brown County Contact: Thomas Tracy 217/773-4411	FACILITY - name and address where tanks are located: DOT Foods, Inc. 251 Central Avenue University Park, IL 60484 Will County Contact: Blake Ryan 847/227-6600
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	10,000	Tank Not Installed	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Spill Containment Device	Double Wall Spill Bucket	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Corrosion Protection - Tank	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Tank	Fiberglass Double Wall XERXES	New
Piping	Flexible Double Wall A.P.T. Poly Tech P175SC	New
Piping	Ball Valves	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispensers on the Permit

Dispenser	Action
1	Replacing - 1
2	Replacing - 2
3	Replacing - 3
4	Replacing - 4
5	Replacing - 5

Dispenser 1 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser 2 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser 3 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser 4 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser 5 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions. There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

Adding a 10,000-gallon On-Road Diesel tank to manifold with the existing On-Road Diesel tank.

Special Contingencies

NOTE: Vent line shown but must meet section 175.440 of our rules

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: jim.veverka@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Daniel Starks