



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2044612
Permit #: 00754-2024UPG
Request Rec'd: 06/24/2024
Approval Date: 06/24/2024
Permit Expires: 12/24/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: City of Chicago Department of Water Management 1000 East Ohio Street Commissioner's Office Chicago, IL 60611 Cook County Contact: Chamoon Anawes 312/747-7154	FACILITY - name and address where tanks are located: Lexington Pumping Station 5555 W. Lexington Street Chicago, IL 60644 Cook County Contact: Robert Mussen 630/834-0100
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
2	Diesel Fuel	30,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Change out spill buckets due to failed hydrostatic testing.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
K Plus Mechanical 10220 Bode St. Unit A Plainfield, IL 605851632	Contact Person: Tim Smith Phone: 815/216-7715 Email: tsmith@kplusmechanical.com Contractor License # IL002455 Exp. 10/26/2024

Sincerely,

Sean Keane