



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2013986
Permit #: 00418-2024ABN
Request Rec'd: 03/29/2024
Approval Date: 04/15/2024 DS
Amended Date: 06/26/2024 DS
Permit Expires: 10/16/2024

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Borden Chemical Inc 180 E Broad St Columbus, OH 43215 (None) County Contact: Krause Jeffrey 630/575-5705	FACILITY - name and address where tanks are located: Borden Chemical Inc 1401 S Circle Ave Forest Park, IL 60130 Cook County Contact: Jeff Krause 630/575-5705
--	---

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
61	20,000	Methylene Diphenyl Diisocyanate	Inert material mixed with portland cement	
62	20,000	Methylene Diphenyl Diisocyanate	Inert material mixed with portland cement	
63	20,000	Methylene Diphenyl Diisocyanate	Inert material mixed with portland cement	
64	20,000	Hazardous Substance	Inert material mixed with portland cement	
65	20,000	Naptha	Inert material mixed with portland cement	
66	12,000	Naptha	Inert material mixed with portland cement	
67	12,000	Hazardous Substance	Inert material mixed with portland cement	
68	12,000	Kerosene	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

Abandonment of 8 USTs and all asociated tank piping due to location in basement inside warehouse building

Special Contingencies

Amendment Reason:

6/26/2024 Permit 00418-2024ABN with supplemental information

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Daniel J. Starks

Daniel Starks