

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2024384
Permit #: 00770-2024UPG
Request Rec'd: 06/26/2024
Approval Date:06/27/2024 DS
Permit Expires: 12/27/2024

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Lehigh Gas Wholesale Services 645 Hamilton, Suite 400 Allentown, PA 18101 (None) County

Contact: Jeremy Holland 610/625-8061

**FACILITY** 

- name and address where tanks are located:

IL-0085

847 N. Sheridan Rd.

Winthrop Harbor, IL 60096

Lake County

Contact: Jaison Thomas 224/789-5133

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal

### **Tank 1 Equipment**

<b>Equipment Type</b>	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Mechanical Other Non-vented check valve	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection

#### **Summary of Work**

Remove existing STP sump, STP and leak detector. Install new STP sump, STP and Leak Detector

## **Special Contingencies**

Daniel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/978-9937 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026			

Sincerely,

**Daniel Starks**