



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605  
**Amended**

FOR OFFICE USE ONLY  
Facility # 5-012508  
Permit # 00029-2006CAT  
Request Rec'd 01/03/2006  
Amended Date 02/21/2006  
Approval Date 1/5/2006 MB  
Permit Expires 7/5/2006

**Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Creekside Corner LLC P.O. Box 236 Rochester, IL 62563  Contact: Mark Walker	<b>(2) FACILITY</b> - name and address where tanks are located:  Creekside Corner LLC 320 East Main, P.O. Box 236 Rochester, Sangamon Co., IL  Contact: Mark Walker (217) 498-7439
--	--

**(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:**

- (a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired:* (TK # 2) - 2,000 gallons, (TK # 5) - 8,000 gallons
- (b) *Type of tanks:* (TK # 2) - Existing single wall STI P3, (TK # 5) - Existing double wall fiberglass, (TK # 5) Existing Existing single wall fiberglass
- (c) *Type of piping:* (TK # 2, 5) - Existing single wall fiberglass, (TK # 5) - Existing single wall steel
- (d) *Product to be stored in each tank:* (TK # 2) - Diesel Fuel, (TK # 5) - Gasoline
- (e) *Type of leak detection being used:*  
*Tank:* (TK # 2, 5) - Existing automatic tank gauging  
*Piping:* (TK # 5) Existing Existing European Suction
- (f) *Corrosion Protection being used:*  
*Tank:* \_\_\_\_\_  
*Piping:* (TK # 2, 5) - Existing fiberglass, (TK # 5) - (Installing) Sacrificial anodes cathodic protection, (TK # 5) Existing Existing non-corrosive flexible
- (g) *NACE certified designer:* \_\_\_\_\_ *Certification number:* \_\_\_\_\_
- (h) *Method of integrity assessment of tank(s) being used:* \_\_\_\_\_

- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:** \_\_\_\_\_

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  _____ _____ _____	Contact Person: _____ Phone: _____ Contractor Registration # _____ Exp. _____
--	---

Sincerely,

\_\_\_\_\_  
Mark Blough

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)