



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	3045558
Permit #:	00774-2024UPG
Request Rec'd:	07/01/2024
Approval Date:	07/01/2024 DS
Permit Expires:	01/02/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Hy-Vee, Inc. 5820 Westown Parkway West Des Moines, IA 50266 Polk County Contact: Wade Meyer 515/267-2800	<b>FACILITY</b> - name and address where tanks are located: Hy-Vee Gas 5421 W. War Memorial Drive Peoria, IL 61615 Peoria County Contact: Zach Ebersole 309/692-2549
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Mid-grade	20,000	Currently in use	Federal
2	Gasoline - Regular	8,000	Currently in use	Federal
3	Gasoline - Premium	6,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

Replacing existing single wall spill manholes with double wall spill manholes.  
 This work is necessary due to the inability to remove overfill drop tube valves from the existing spill manholes.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks