



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 7032182
Permit #: 00671-2024UPG
Request Rec'd: 06/03/2024
Approval Date: 06/03/2024 DS
Amended Date: 07/02/2024 DS
Permit Expires: 12/03/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Tim & Melissa Parsons P.O. Box 753 Carbondale, IL 62903 Jackson County Contact: Tim Parsons 618/713-6991	FACILITY - name and address where tanks are located: Four Way Quick Stop, LLC 200 North Chestnut De Soto, IL 62924 Jackson County Contact: Kelly Hartman 618/867-2211
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	4,000	Currently in use	Federal
3	Gasoline - Mid-grade	4,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New
Piping	Flex Connector Steel	New
Piping	Steel Single Wall Piping	New
Spill Containment Device	Double Wall Spill Bucket	New
Piping	Other Steel Riser	Replacing - Piping - Fiberglass Single Wall Piping

Dispensers on the Permit

Dispenser	Action
5/6	Sump / Sensors Changing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Summary of Work

The existing emergency valve was replaced under an emergency permit. This dispenser has no sump so we are installing a dispenser sump, modifying the existing singlewall product piping, flex connector and emergency valve (if required, a new emergency valve was just installed and this dispenser was not re-opened afterwards so it should be in good shape). A new island will be installed and the existing dispenser re-used.

Special Contingencies

Amendment Reason:


changing the probe riser and upgrading to a double wall spill bucket.

PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
128 Millwell Drive
Maryland Heights, MO 63043

Contact Person: Terry Smith
Phone: 314/797-0468
Email: cbayne@unitedpetro.com
Contractor License # IL002402 Exp. 2/10/2026

Sincerely,



Daniel Starks

For Office Use Only

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing