

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2012725
Permit #: 00785-2024CAT
Request Rec'd: 07/03/2024
Approval Date:07/03/2024 DS
Permit Expires: 01/03/2025

# <u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Exron Capitol, Inc. 3340 S. Harlem Ave. Riverside, IL 60546 Cook County

Contact: Matthew Speiser 630/560-7803

**FACILITY** 

- name and address where tanks are located:

Minuteman Citgo 205 N. Main Street Wauconda, IL 60084 Lake County

Contact: Jerri Blanton 847/526-0860

## Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Diesel Fuel	8,000	Currently in use	Federal

# **Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection -	Sacrificial Anode Cathodic	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex
Piping	Protection - STP	Connector - STP

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

#### **Special Contingencies**

### **Summary of Work**

Install (1) 9lb anode in diesel tank 9 STP sump.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, LLC 658 North Progress Drive PO Box 80265

Janiel J. Starke

Saukville, WI 53080

Contact Person: Kylie Krombach

Phone: 262/268-1150 Email: leeh@protanicinc.com

Contractor License # IL1413 Exp. 3/15/2026

Sincerely,

Daniel Starks