



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 4024307
Permit #: 00693-2024UPG
Request Rec'd: 06/06/2024
Approval Date: 06/06/2024 DS
Amended Date: 07/05/2024 DS
Permit Expires: 12/06/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: GDM Properties, LLC 6 Lunt Avenue Schaumburg, IL 60193 (None) County Contact: Elizabeth Sauser 210/692-2224	FACILITY - name and address where tanks are located: Mac's #1207 11 East Northbrook Drive Dwight, IL 60420 Livingston County Contact: Vicky Hooper 812/379-9227
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	10,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New

Summary of Work

REPLACE T6 DIESEL 4" PIPE RISER THAT COMES OFF THE EXTRACTOR

AMENDING TO INCLUDE:

installing opw 233 extractor valve

we are cutting the vent at the diesel tank to install a new extractor valve. then will test.

Special Contingencies

Amendment Reason:

amend to cut vent at tank to install new extractor

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026

Sincerely,

Daniel Starks