



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2005467  
Permit #: 00789-2024UPG  
Request Rec'd: 07/03/2024  
Approval Date: 07/05/2024 DS  
Permit Expires: 01/07/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60642 Cook County Contact: Roy Hupke 708/229-5241	<b>FACILITY</b> - name and address where tanks are located: Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60805 Cook County Contact: William Heisterman 708/229-5241
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	10,000	Currently in use	Federal

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Summary of Work**

Installing a new Veeder Root Overfill Alarm and acknowledgement switch.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 5/16/2026

Sincerely,

Daniel Starks