

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 2018627
Permit #: 00798-2024UPG
Request Rec'd: 07/08/2024
Approval Date: 07/08/2024 DS
Amended Date:07/08/2024 DS
Permit Expires: 01/08/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Material Sciences Corporation 2300 East Pratt Boulevard Elk Grove Village, IL 60007

Cook County

Contact: Ed Kolozsy 847/849-9147

FACILITY

- name and address where tanks are located:

Material Sciences Corporation

2300 E. Pratt Blvd.

Elk Grove Village, IL 60007

Cook County

Contact: Ed Kolozsy 847/849-9147

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Glycol Ether	3,000	Currently in use	Federal
11	Methyl Ethyl Ketone	3,000	Currently in use	Federal
12	Methyl Ethyl Ketone	5,000	Currently in use	Federal

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing 4 single wall spill containers with double wall spill containers. Tanks selected on Permit are 9, 11, and 12. However, we will be upgrading Tank 10 as well, but there was no option to select it.

Special Contingencies

Amendment Reason:

We will be changing Tank 10's existing single wall spill container with a double-wall spill container, but the tank is not listed as a regulated tank. I could not select that tank to show the changes that will be made on it.

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company 2939 175th Street Lansing, IL 60438

Contact Person: Ed Angell Phone: 708/474-3344

Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely, Daniel J. Starks

Daniel Starks