



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2021115
Permit #: 00813-2024UPG
Request Rec'd: 07/10/2024
Approval Date: 07/10/2024 DS
Permit Expires: 01/10/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: RDK Ventures, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 Du Page County Contact: Elizabeth Sauser 708/748-3496	FACILITY - name and address where tanks are located: Circle K #6734 50 West Lake Cook Road & Route 83 Buffalo Grove, IL 60089 Lake County Contact: Desai Jitendra 812/379-9227
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Gasoline - Regular	12,000	Currently in use	Federal
3	Gasoline - Premium	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser - ATG Riser	New
Piping	Other Steel Riser - Fill Riser	New
Piping	Other Steel Riser - Vapor Riser	New
Piping	Other Steel Riser - STP Riser	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Submersible Pump	New
Piping	Other Steel Riser - ATG Riser	New
Piping	Other Steel Riser - Fill Riser	New
Piping	Other Steel Riser - Vapor Riser	New
Piping	Other Steel Riser - STP Riser	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser - ATG Riser	New
Piping	Other Steel Riser - Fill Riser	New
Piping	Other Steel Riser - Vapor Riser	New
Piping	Other Steel Riser - STP Riser	New

Summary of Work

Tank lining inspections have been completed by Armor Shield. Tank testing can not be done until everything in the "one sumps" can be re-assembled. All of the risers on All (3) tanks are rusted out. All new risers need to be installed so everything can be re-assembled and tank testing can be performed. OSFM inspector Dan was on site for the tank lining inspections and is aware of this situation along with Aaron Siegler, who has been informed also. Installing new Fill, Vapor, STP and ATG Risers within the "one sumps" of All (3) tanks. Installing new submersible on West RUL (#2) tank.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: keith@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks