



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2047770
Permit #: 00829-2024REM
Request Rec'd: 07/12/2024
Approval Date: 07/15/2024 DS
Permit Expires: 01/15/2025

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Mitch Goltz 2211 N. Elston Avenue Suite 400 Chicago, IL 60614 Contact: Mitch Goltz 773/382-0445	FACILITY - name and address where tanks are located: 2777 Mannheim Rd 2777 Mannheim Road Des Plaines, IL 60018 Cook County Contact: Mitch Goltz 773/382-0445
--	---

Tanks on the Permit

Tank #	Capacity	Product	Last Used Date
1	1,600	Heating Oil	12/31/1973

Summary of Work

Excavate to expose tank. Remove cap pump remaining liquids from tank. Vent or inert tank. Test LEL or % oxygen - when below 5 % excavate to free tank. If above %5 continue to vent or inert. Hoist tank with backhoe. Place tank on poly. Retest tank, when less than 5% cut an opening in tank and clean tank. Use non-sparking tools. place tank on trailer and transport to scrap yard. Obtain required soil samples. Replace backfill and depart site.

Special Contingencies

The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Environmental Protection Industries, Inc. 16650 South Canal Street South Holland, IL 60473	Contact Person: Eryn Barba Phone: 773/456-6015 Email: dhaughewald@environmental-epi.com Contractor License # IL564 Exp. 6/27/2026

Sincerely,

Daniel Starks