



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	7032042
Permit #:	00831-2024CAT
Request Rec'd:	07/12/2024
Approval Date:	07/15/2024 DS
Permit Expires:	01/15/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	FACILITY - name and address where tanks are located: Casey's General Store #1727 400 N. 4th Street Elkhville, IL 62932 Jackson County Contact: Tienielle Worthington 515/965-6238
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks


Special Contingencies

Summary of Work

Replace the depleted sacrificial anode in the DSL STP (flex connector)

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Protanic, LLC 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Kylie Krombach Phone: 262/268-1150 Email: danc@protanicinc.com Contractor License # IL1413 Exp. 3/15/2026

Sincerely,



Daniel Starks