



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 312/745-3162
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2038282
Permit #:	00837-2024UPG
Request Rec'd:	07/15/2024
Approval Date:	07/16/2024
Permit Expires:	01/16/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Roseland Community Hospital 45 West 111th Street Chicago, IL 60628 Cook County Contact: Bob Piwowar 773/995-3481	FACILITY - name and address where tanks are located: Roseland Community Hospital 45 West 111th Street Chicago, IL 60628 Cook County Contact: Main Number 773/995-3481
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	European with No Test Req Suction	Replacing - Leak Detect - Piping - American with Annual Prec Line Testing Suction

Summary of Work

Piping on this tank is European Safe Suction, not American Suction. This has been confirmed through multiple tank tests over the years by Tanknology.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Tanknology 880 Church Road Elgin, IL 60123	Contact Person: Linda Przydzial Phone: 847/888-4836 Email: bdaliego@tanknology.com Contractor License # IL2089 Exp. 3/4/2026

Sincerely,

Sean Keane