



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2032033
Permit #: 00843-2024ABN
Request Rec'd: 07/16/2024
Approval Date: 07/16/2024
Permit Expires: 01/16/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois Institute of Technology 100 W. 33rd Street Chicago, IL 60616 Cook County Contact: Bruce Watts 312/567-7132	FACILITY - name and address where tanks are located: Illinois Institute of Technology 3430 S. Federal Street Chicago, IL 60616 Cook County Contact: Steve Bartley 312/567-8687
---	---

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
2	60,000	Diesel Fuel	Inert material mixed with portland cement	Fill in place with slurry

Explanation of Waiver for Abandonment

Built-in-place UST is located adjacent to several structures including ITT Smokestack, elevated Metra Rock Island rail and metra stairs/handicap ramp. Removal of tank this size may compromise these structures.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: ademauro@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Sean Keane